

# Clinical Laboratory of San Bernardino, Inc.

Celebrating 50 Years of Analytical Service 1967-2017



Fullerton, City of  
303 W. Commonwealth Ave.  
Fullerton CA, 92832

Project: School Lead Program  
Sub Project: Lead Sampling for FSD / FSD Nutrition Center  
Project Manager: Louis Gonzalez

Work Order: 18H2205  
Received: 08/23/18 15:30  
Reported: 09/07/18

**3010010-ACI-A** **18H2205-01 (Water)** **Sample Date:** 08/23/18 5:55 **Sampler:** Not Listed

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

**Metals**

Lead (Pb) EPA 200.8 ND 25 15 ug/L 09/06/18 09/06/18 1836086

**3010010-ACI-B** **18H2205-02 (Water)** **Sample Date:** 08/23/18 5:55 **Sampler:** Not Listed

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

**Metals**

Lead (Pb) EPA 200.8 ND 5.0 15 ug/L 09/06/18 09/06/18 1836086

**3010010-ACI-C** **18H2205-03 (Water)** **Sample Date:** 08/23/18 5:59 **Sampler:** Not Listed

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

**Metals**

Lead (Pb) EPA 200.8 **18** 5.0 15 ug/L 09/07/18 09/07/18 1836139

**3010010-ACI-D** **18H2205-04 (Water)** **Sample Date:** 08/23/18 6:01 **Sampler:** Not Listed

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

**Metals**

Lead (Pb) EPA 200.8 **11** 5.0 15 ug/L 09/06/18 09/06/18 1836086

ND Analyte NOT DETECTED at or above the reporting limit

Stu Styles  
Client Services Manager

# Clinical Laboratory of San Bernardino, Inc.

## EDT Transfer Confirmation 1



Work Order: 18H2205  
Report Date: 09/07/2018  
Analyzing Lab: Clinical Laboratory of San Bernardino, Inc. ELAP 1088

Page 1 of 1

CITY OF FULLERTON		User ID: TEE	System: 3010010
Fullerton School Dis-Sink - for fruits a	Station No.: 3010010-ACI-A	Sampled: 180823 05:55	
LEAD	Result: ND Units: UG/L	Entry No.: 01051	Analyzed: 180906
Fullerton School Dis-Ice Maker	Station No.: 3010010-ACI-B	Sampled: 180823 05:55	
LEAD	Result: ND Units: UG/L	Entry No.: 01051	Analyzed: 180906
Fullerton School Dis-Kettle 1	Station No.: 3010010-ACI-C	Sampled: 180823 05:59	
LEAD	Result: 18 Units: UG/L	Entry No.: 01051	Analyzed: 180907
Fullerton School Dis-Kettle 2	Station No.: 3010010-ACI-D	Sampled: 180823 06:01	
LEAD	Result: 11 Units: UG/L	Entry No.: 01051	Analyzed: 180906

